



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-8531BR0333

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG, Sanitär- und Heizungssysteme Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG, Sanitär- und Heizungssysteme Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	installation systems and system joints: Compression joint for metallic gas pipes (8531)
Product Description <i>Produktbezeichnung</i>	gas installation system consisting of pressing joints Sanpress Inox G with SC-contour (leaky in the nonpressed state) made of stainless steel and pipes made of stainless steel
Model <i>Modell</i>	Sanpress Inox G
Test Reports <i>Prüfberichte</i>	laboratory control test: 120000428-14 from 21.11.2014 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW G 5614 (01.12.2013)

Date of Expiry / File No. 20.03.2020 / 15-0028-GNA
Ablaufdatum / Aktenzeichen

18.02.2015 Rie A-1.2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 15,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 18,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 22,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 28,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 35,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 42,0 mm	
02...	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 54,0 mm	
02...XL	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 64,0 mm	
02...XL	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 76,1 mm	
02...XL	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 88,9 mm	
02...XL	nominal pressure rating: MOP 5 / GT 5 nominal diameter: 108,0 mm	

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

Stainless steel pipes to use: „Sanpress Rohr 1.4401“, Viega GmbH & Co. KG, D-57439 Attendorn.

The requirements of the higher thermal resistance (HTB) are fulfilled up to nominal pressures of MOP 5 (GT 5).

The basis of this certification are the pressing tools of the company Viega GmbH & Co. KG, D-57439 Attendorn.
